

Table 5-3a Distribution network supply Security Standard

Class	Description of Area or Customer type	Size of load (MW)	Cable, line or transformer fault	Double cable, line or transformer fault	Bus or switchgear fault
Transpower GXP					
A1	GXP supplying CBD, commercial or special industrial customers	15-600	No interruption	Restore within 2 hours	No interruption for 50% and restore rest within 2 hours
B1	GXP supplying predominantly metropolitan areas (suburbs or townships)	15-600	No interruption	Restore within 2 hours	No interruption for 50% and restore rest within 2 hours
C1	GXP supplying rural and semi rural areas	15-60	No interruption	Restore within 4 hours ^(Note 1)	No interruption for 50% and restore rest within 4 hours ^(Note 1)
D1	GXP in remote areas	0-1	Restore in repair time	Restore in repair time	Restore in repair time
Orion 66kV and 33kV subtransmission network					
A2	Supplying CBD, commercial or special industrial customers	15-200	No interruption	Restore within 1 hour	No interruption for 50% and restore rest within 2 hours
A3	Supplying CBD, commercial or special industrial customers	2-15	Restore within 0.5 hour	Restore 75% within 2 hours and the rest in repair time	Restore within 2 hours
B2	Supplying predominantly metropolitan areas (suburbs or townships)	15-200	No interruption	Restore within 2 hours	No interruption for 50% and restore rest within 2 hours
B3	Supplying predominantly metropolitan areas (suburbs or townships)	1-15	Restore within 2 hours	Restore 75% within 2 hours and the rest in repair time	Restore within 2 hours
C2	Supplying predominantly rural and semi-rural areas	15-200	No interruption	Restore within 4 hours ^(Note 1)	No interruption for 50% and restore rest within 4 hours ^(Note 1)
C3	Supplying predominantly rural and semi-rural areas	4-15	Restore within 4 hours ^(Note 1)	Restore 50% within 4 hours and the rest in repair time ^(Note 1)	Restore within 4 hours ^(Note 1)
C4	Supplying predominantly rural and semi-rural areas	1-4	Restore within 4 hours ^(Note 1)	Restore in repair time	Restore 75% within 4 hours and the rest in repair time ^(Note 1)
Orion 11kV network					
A4	Supplying CBD, commercial or special industrial customers	2-4	Restore within 0.5 hour	Restore 75% within 2 hours and the rest in repair time	Restore within 2 hours
A5	Supplying CBD, commercial or special industrial customers	0.5-2	Restore within 1 hour	Restore in repair time	Restore 90% within 1 hour and the rest in 4 hours (use generator)
A6	Supplying CBD, commercial or special industrial customers	0-0.5	Use generator to restore within 4 hours	Restore in repair time	Use generator to restore within 4 hours
B4	Supplying predominantly metropolitan areas (suburbs or townships)	0.5-4	Restore within 1 hour	Restore in repair time	Restore 90% within 1 hour and the rest in 4 hours (use generator)
B5	Supplying predominantly metropolitan areas (suburbs or townships)	0-0.5	Use generator to restore within 4 hours	Restore in repair time	Use generator to restore within 4 hours
C5	Supplying predominantly rural and semi-rural areas	1-4	Restore within 4 hours ^(Note 1)	Restore in repair time	Restore 75% within 4 hours and the rest in repair time ^(Note 1)
C6	Supplying predominantly rural and semi-rural areas	0-1	Restore in repair time	Restore in repair time	Restore in repair time
Note 1. Assumes the use of interruptible irrigation load for periods up to 48 hours.					